



Program WWF
Program ID# 05-0158
Facility ID# 84069
File Category (G,PR) P

COPY

STATE OF NEBRASKA

Dave Heineman
Governor

DEPARTMENT OF ENVIRONMENTAL QUALITY
Michael J. Linder
Director

Suite 400, The Atrium
1200 'N' Street

P.O. Box 98922

Lincoln, Nebraska 68509-8922

Phone (402) 471-2186

FAX (402) 471-2909

website: www.deq.state.ne.us

Mr. Pat Tracy
E3 BioFuels
4780 S. 131st Street
Omaha NE 68137

JUL 14 2006

RE: Addendum No. 1
Phase-V(1), Emergency Overflow Pond for the Solid Waste Management System
E3 BioFuels Ethanol Plant, Mead, Saunders Co.

STATE CONSTRUCTION PERMIT NO. 05-0158-05

Dear Mr. Tracy:

We have reviewed Addendum No. 1 for the above referenced project. This addendum proposes modifying Sheet 1.5 – Ethanol Plant Overflow Pond by Settje Agri-Services & Engineering to add two valves and piping that will allow emergency diversion of thin stillage around the anaerobic digestion process to the synthetically-lined emergency overflow pond, with the thin stillage to be pumped back to the influent tank of the anaerobic digestion process upon resumption of normal operations. The proposed addendum is found to be acceptable.

The approval previously granted for the plans and specifications under Construction Permit No. 05-0158-05 dated May 15, 2006, is hereby extended to cover this addendum.

Three copies of Addendum No. 1 have been stamped approved and are being returned to the submitting engineer for distribution and attachment to the original documents. One approved copy is being retained for the Department's records.

If you have questions, please contact me at (402) 471-4206 or Rick Hoopes at (402) 471-2589.

Sincerely,

Charles Duerschner

Charles Duerschner, P.E.
Supervisor, Technical Assistance Unit
Wastewater Section, WQD

CAD/rkh

pc: Frank Freeman, Dilling Mechanical Contractors (w/ 3 copies of Addendum #1)

pc: Ryan Brandt, Settje Agri-Services & Engineering



20060049572