



**Dave Heineman**  
Governor

# FILE COPY

## STATE OF NEBRASKA

**DEPARTMENT OF ENVIRONMENTAL QUALITY**  
**Michael J. Linder**  
Director

Suite 400, The Atrium  
1200 'N' Street  
P.O. Box 98922  
Lincoln, Nebraska 68509-8922  
Phone (402) 471-2186  
FAX (402) 471-2909  
website: [www.deq.state.ne.us](http://www.deq.state.ne.us)

DEC 08 2005

Mr. Pat Tracy  
Nebraska BioClean  
4780 S. 131<sup>st</sup> Street  
Omaha NE 68137

RE: Phase III, Anaerobic Digester System, Solid Waste Management System  
Nebraska BioClean Ethanol Plant, Mead, Saunders Co.

STATE CONSTRUCTION PERMIT NO. 05-0158-03

Dear Mr. Tracy:

Pursuant to Neb. Rev. Stat. Sec. 81-1506 (2) (Reissue 1994), documents describing this project have been approved and stamped accordingly. One set of documents is being retained for this Department's records, and the rest are being returned to the **submitting engineer** for distribution, including a construction certification card to be returned to this Department.

**This construction permit is for the Phase III anaerobic digester system only. No other construction work such as Phase IV Biogas System, Phase IV Nutrient Removal System, or Phase V Lagoon and Water Distribution System is included in this permit.**

Compliance with minimum sanitary engineering design criteria was the only consideration in the review of this project, as only sanitary related documents were reviewed, unless specifically noted in review comments. **This construction permit does not supersede any required local review or permit**, nor release the owner from the responsibility of providing an operable facility. If significant changes are needed during construction, change orders must be submitted to this Department, and as-built plans may be required. Please refer to our construction permit number.

The undersigned issues this document on behalf of the Director in accordance with Title 123 – Rules and Regulations for Design, Operation and Maintenance of Wastewater Treatment Works.

**If you have questions, please contact Charles Duerschner, P.E., Supervisor, Technical Assistance Unit, at (402) 471-4206.**

Sincerely,

Patrick W. Rice  
Assistant Director

PR/CAD/rkh

pc: Frank Freeman, P.E., Dilling Mechanical Contractors, Inc., Fort Wayne, IN

