


An Aquifer Storage and Recovery System in Hastings, NE


Amanda Jones
Nebraska Department of
Environmental Quality

Background

Hastings, NE




Regional Ground Water Movement



• 3


Hastings Water System



- Supplies water to the City of Hastings, NE and some smaller surrounding communities
- Established mid 1880's
 - Oldest operational well was constructed in 1915
- No water treatment in place
- 17/33 municipal wells are currently operational and in use
 - 9 lost due to nitrate contamination
 - 7 lost due to VOC contamination
- **Non-centralized system** (all wells service separate zones)

• 4

Hastings Water System



Ground Water Quality Issues

Major Issues

- Nitrate
- Uranium
- Gross Alpha
- Selenium
- pH
- Hardness

Minor Issues

- Atrazine detected at low levels
- Increasing inorganic levels

Solutions

- Defining the issues
- Continued monitoring and modeling
- Nitrate Management Plan
- Hastings ASR Project
 - Dual pumping technology(DPT)
 - Focused water treatment
 - Blending
 - Storage
 - Irrigation reuse and management in addition to the nitrate management plan

•

•7


Timeline

- 1997: Initial ground water and contaminant modeling by Layne Geoscience
- 2009: Updated modeling by HDR Engineering
- 2010: 1st UNL vadose zone study
- 2010-2011: City of Hastings water sampling
- 2012: Nitrate Management Plan adopted
- 2015: 2nd UNL vadose zone study
- 2015-2016: City of Hastings water sampling
- 2018: Hastings ASR Permit Issued, injection well construction
- 2021: 3rd UNL vadose zone study planned

•

•8


Defining the Issues



Nitrate Management Plan

- Adopted by Hastings in 2012
- 106 square miles included, roughly the same area as the Hastings WHPA
- Includes:
 - Training
 - Soil sampling and reporting
 - Rate and timing of fertilizer application
 - Promotes water conservation (limit movement of N)

Nitrate Management Plan



● 11

Hastings ASR Project

- Funding
- Modeling Study
- Pilot Study: ASR5
- Five permitted ASR wells
- Inject into the Quaternary Aquifer (100-200 ft bgs)
- Multiple components
 - Dual pumping technology(DPT)
 - Focused water treatment
 - Blending
 - Storage
 - Irrigation reuse and management in addition to the nitrate management plan

● 12

What are the Costs?

<p style="text-align: center;">Conventional Treatment Options</p> <ul style="list-style-type: none"> • Would require centralizing the system! • Conventional RO only treatment for existing water system, construction costs: \$72 million • Conventional IX only treatment for existing water system, construction costs: \$57 million • Projected 20-year O&M costs + capital for conventional methods: \$100 million 	<p style="text-align: center;">Hastings ASR Option</p> <ul style="list-style-type: none"> • Estimated Hastings ASR project, construction costs: \$46 million • Operation and maintenance cost: \$1.3 million/year • Projected 20-year O&M costs + capital for ASR methods: \$72 million
---	--

● 13

Total Est. Construction: \$46 million Total Operating and Maintenance: \$1.3 million/year




Funding

- Clean Water State Revolving Loan Fund (CWSRF): \$4.42 million, water sustainability funding
- \$100,000/year from LBNRD
- \$50,000 one-time from UBBNRD
- \$150,000 from NET
- Updated water utility rates for Hastings residential customers effective Oct. 1, 2016


● 14

Dual Pumping Technology


- Dual Pumping Technology uses two pumps located in the same casing to withdraw water from the top and bottom of the aquifer
- Higher nitrate concentrations are near the top of the aquifer
- Hastings claims DPT will allow for the extended useful life of existing wells and delay/minimize water treatment needed
- Municipal Well 16 has undergone a successful dual pumping test period
- Pump wells used for the ASR project will use DPT (converted or built)

• 17

Dual Pumping Technology



• 18



Focused Water Treatment & Blending

- Reverse Osmosis (RO) treatment to remove nitrates
- Absorbent media used to remove uranium as needed
- If lower aquifer water meets certain contaminant criteria it may bypass treatment
- Blending of waters from high and low nitrate wells if needed

Storage



- A lined water storage pit near the treatment facility has been constructed for ASR water
- Total water storage: 130 acre-feet
- Stored water can be used for irrigation: enough to water from 1 center pivot at 12 inches/year


●21

Irrigation Reuse and Management

- Higher nitrate ASR water is sent to the storage pit following treatment
- Adjoining cropland is partnered with Hastings to use the water for irrigation
- Because the water has higher nitrate levels:
 - Replaces use of normally-pumped, non-treated ground water
 - Replaces the use of fertilizer
 - Crops should benefit from higher nitrate concentrations

●22

Hastings ASR Project



23

Operating Data (Proposed/Permitted)

- Volume of injectate:
 - Average: 2000 gpm
 - Maximum: 2600 gpm
- Permit Limitations
 - Injection Pressure: 100.0 psig
 - Max Daily Injection Volume: Report
 - Max Daily Injection Rate: Report
 - Average Daily Injection Rate: Report
 - Nitrate (as N): 10.0 mg/L
 - Uranium: 0.03 mg/L
 - Arsenic: 0.01 mg/L
 - Drinking water quality limitations parameter suite

24

Hastings ASR Conclusions

- Hastings hopes their ASR project will overall improve the quality of drinking water while keeping long-term costs lower than they would be for conventional treatment
- Permit issued by the NDEQ: January 10, 2018
- Injection well construction late January
- Estimated system start-up date of late winter-early spring 2018

•

•25

Questions?

•

•26